

**SUMMARY OF CHANGES
To Water Tank**

All REV D changes are in BOLD type.

Cover Sheet

1. **Changed third sentence in Paragraph 1.A.**
2. **Changed Paragraph 1.C.3.**
3. **Added Paragraph 1.E and renumbered remaining paragraphs.**
4. **Added Paragraph 9.**
5. **Added Paragraph 10 and renumbered remaining paragraphs.**
6. **Changed ACS to ATA in Paragraph 11.**

SUMMARY OF CHANGES To Water Tank

Specifications

Section 01010

1. Added sentence to Paragraph **1.1.A (added OPTION and changed logo to graphics).**
2. Added Paragraph 1.1.D and renumbered next paragraph
3. Changed ASSE A14.3 to ANSI A14.3
4. Changed wording in Paragraph 1.1.E and added OSHA Standard, changed wording in Paragraph 1.1.E.3 and renumbered remaining paragraph, added wording to Paragraph 1.1.E.5.
5. Removed last sentence of Paragraph 1.1.E "All ladders to match existing appearance and placements. Dispose of demolished ladders per Government representative."
6. Added OSHA and ANSI standards to Paragraph 1.1.F.
7. Added Paragraph 1.1.G and renumbered remaining paragraphs.
8. Added 29 CFR 1910.23, 29 CFR 1926.501, 29 CFR 1926, 502 to Paragraph 1.4.E.

Section 01060

1. Added 29 CFR 1910.23, 29 CFR 1926.501, 29 CFR 1926, 502, and 29 CFR 1926.1053.
2. Changed ASSE A14.3 to ANSI A14.3.
3. Added AWS D1.1.

Section 01340

1. Added number 27 and renumbered remaining submittals.

Section 05500

1. Added Paragraph 1.2.B.
2. Deleted ASTM A307 and added ASTM A325 to Paragraph 1.3.B.4.
3. Added Paragraph 3.3.G.

Section 05511

1. Changed first sentence in Paragraph 1.1.A.
2. Added Paragraph 1.1.A.3.
3. Changed Paragraph 1.1.A.4.
4. Added Paragraphs 1.1.A.8 and .9.
5. Added Paragraph 1.1.B.3.
6. Changed ASSE A14.3 to ANSI A14.3.
7. Added 29 CFR 1910.23, 29 CFR 1926.501, 29 CFR 1926, 502, and 29 CFR 1926.1053.
8. Added sentence to Paragraph 1.3.B.
9. Added Paragraph 1.3.C

10. Added Paragraph 2.1.B and renumbered remaining paragraphs
11. Added OSHA 29 CFR 1926.1053 and ANSI A14.3 to Paragraph 2.2.A
12. Added Paragraph 2.2.B, 2.2.C, and 2.2.D and renumbered remaining paragraphs
13. Added Paragraph 3.1.C and renumbered remaining paragraphs.
14. Added Paragraph 3.1.F.

Section 09900

1. Added Paragraph 1.1.G (**Rev D Added OPTION**)
2. Added Paragraph 1.1.C and renumbered remaining paragraphs.
3. **Added Option to end of Paragraph 1.2.C**

Appendix 1

Page 8 of 9

1. Changed Paragraph 4 to include railings and platforms and color.

Page 9 of 9

1. Changed Paragraph 2: Added "and new steel" and G.

Attachment A

1. Added Attachment A, **Added OPTION to sheet.**

Changes to Drawings:

1. Dwg. A1. Changed note 1 to "Refer to Specification No. ANZY020040."
2. Dwg. A1. Add requirements to Note 2 "29 CFR 1910.27 and 1926.1053."
3. Dwg. A1. Change Note 11 to "Exterior vertical ladder, tank interior ladder and tank exterior ladder width 24". Riser ladder width 16". Transition ladder width, 16".
4. Dwg. A1. Changed Ladder and Carrier Rail Details to clarify that all ladders are to be new and have fall protection. Revolving dome ladder is to be demolished and replaced with a new ladder and platform. Also safety chains are to be provided on either side of the hatch opening. Side rails for the transition ladder are to be extended through the hatch opening.
5. Dwg. A1. Noted that fall protection details are existing and provided for information only.
6. Dwg. A2. Added Note: "Contractor to field verify balcony height from the floor to the top of the rail."
7. Dwg. A3. Added new Detail: Ladder and Carrier Rail details to show existing dimensions.